

STANDARD SERVICES/AVAILABLE VOLTAGES _____ VIII-A-1

One system of alternating current, 60 Hertz, is supplied throughout the Cooperative's system. The voltage, number of phases and type of metering which will be supplied depends upon the availability of Cooperative facilities and upon the character, size and location of the load to be served. Therefore, the Member shall consult the Cooperative before proceeding with the purchase or installation of wiring or equipment. To avoid misunderstandings, this information should be in writing. The standard secondary voltages described below are nominal and are subject to a plus or minus 6% variation.

Single phase 2 wire		120 volts
Single phase 3 wire		120/240 volts
Three phase	4 wire WYE	120/208 volts
Three phase	4 wire Delta	120/240 volts
Three phase	3 wire Delta	240/480 volts
Three phase	4 wire WYE	277/480 volts

The Cooperative cannot be responsible when voltages outside of the prescribed limits are caused by any of the following:

- a. action of the elements;
- b. service interruptions;
- c. temporary separation of parts of system from main system;
- d. infrequent fluctuations not exceeding five minutes duration;
- e. power supply; and/or
- f. other causes beyond the control of the Cooperative.

Date Originally Adopted: August 13, 2004

INTERRUPTION OF SERVICE _____ VIII-A-2

The Cooperative will use reasonable diligence to provide a regular and uninterrupted supply of current. If the supply of current shall be interrupted for any cause beyond the reasonable control of the Cooperative, the Cooperative shall not be liable for damages resulting therefrom.

Date Originally Adopted: August 13, 2004